

RFB 15-0117  
FENCING CONSTRUCTION AND INSTALLATION  
NEW HANOVER COUNTY LANDFILL

ADDENDUM #1  
RESPONSE TO BIDDER QUESTION

**Question/comment from bidder:**

I would recommend if you are going to set these post out of plumb we use concrete.

**Response from Landfill Manager:**

We are not requiring the use of concrete. The poles only have to be angled in ever so slightly (approximately 3% or so). At this angle it will be evident to the eye, but not enough stress on the fence to cause the poles to topple over.