

NEW HANOVER COUNTY

FINANCE DEPARTMENT
230 Government Center Drive
Suite 165
Wilmington, NC 28403

Telephone: (910) 798-7187
Fax: (910) 798-7806



Lisa Wurtzbacher, CPA
Chief Financial Officer

Barbara D. McClure, CPA
Deputy Chief Financial Officer

Jennifer R. Maready, CPA
Deputy Chief Financial Officer

ADDENDUM # 2

From: Lena L. Butler, Purchasing Supervisor
To: Potential Bidders
Project: 2016-23641-Commercial Grade Equipment for Senior Resource Center
Date: October 2, 2015

This addendum is issued regarding "RFB # 2016-23641-Commercial Grade Equipment for Senior Resource Center" and is hereby made a part of said Request for Bids to the same extent as though it were originally therein.

Item #2- Cold Pan Serving Counter-Will this piece be stainless steel on the outside? **This piece will be stainless steel.** Will a sneeze guard be required? **Yes, a sneeze guard will be required.** If so, a single sided or double sided? **The sneeze guard will be single sided.** Will the sneeze guard need to match the unit next to it? **Yes, the sneeze guard should match the steam table next to it.** Will it need to be attached to the units on either side? **Yes, it will need to be attached.** Will the old unit be removed by the county? **Yes, the old unit will be removed by the County.**

Item #4-Double Deck Gas Convection Oven- Full or 1/2 size unit? **Full size.** Full size takes full sheet pans, 1/2 size does not. Same model as the existing unit? **Same model or comparable unit.**

Item #5- Two Compartment Convection Steamer-Is this to be electric or gas? **Gas** 5 pans per compartment or 5 pans total? **The number of pans will depend on the model. Since there are two compartments, the number of pans will be per compartment. For example, if each compartment holds three pans, the total number of pans would be six.**

Item #6- Mobile Heated Cabinets-Are these to be insulated or un-insulated? **Insulated.** Will we want a double door unit? Or 2 single door units? **Double door unit.**

Item #7-10 ft. Stainless Steel Work Table- Is the depth to be 30"? **Yes, the depth is 30".** Is a backsplash required? **No backsplash is required.** Is it to be a all stainless, fully welded (stronger unit) unit? **Yes, the table is to be stainless, fully welded.**

Item #9 – 10 ft. Beverage Counter-Will this be a stainless counter? **No. We prefer something more aesthetic for the dining area.** Will it have an open front? Or enclosed front with either sliding or hinged

doors? Middle & undershelf? **This will have enclosed front with hinged doors and an under shelf.** Will it have a drink trough? **Yes, a drink trough is required.** If so, how long? **30" long.** If it does, it will need to be plumbed to a drain.

Regarding delivery: Will we be delivering, uncrating, and setting in place ready for final connections (i.e. plumbing, gas, electrical) by the county? **Yes, the vendor is responsible for delivery, uncrating, and setting in place. Final connection (i.e. plumbing, as, electrical) will be performed by County staff.**

Regarding old equipment: Will all of the old equipment be disconnected, and removed from the kitchen by the county? If so, where will it be? Will we be disposing of the old equipment? **The County will disconnect the equipment. The equipment will be removed by the County. The County will also be responsible for disposal. Staff will request that the equipment be declared surplus property and that the equipment be sold via online auction using GovDeals.**