

RFB# DEM 16-003
C&D ELECTRICAL SERVICE
NEW HANOVER COUNTY LANDFILL

Addendum #1
Responses to Bidder Questions

December 8, 2015

1. Section 4: Scope of Work – Item #3 states that the Electrical Contractor is to pick up and install all Duke Energy related gear, including the CT cabinet. Drawing E2.0 indicates the CT Cabinet by the Contractor. Who is responsible to provide and install the CT Cabinet? What Duke Energy gear is the Electrical Contractor to install?

Answer: Due Energy will supply the CT cabinet that will supply their power to the County electrical service equipment. Duke Energy will be running power underground to the site where it will be tied in to the CT cabinet. The contractor shall coordinate with Duke Energy to pick up the CT cabinet and deliver and install at the site.

2. Section 4: Scope of Work – Item #5 states the Electrical Contractor is responsible to supply and install the concrete pad for the pad mounted transformer. Drawing E2.0 indicates the concrete pad is existing. Is the Electrical Contractor to install a concrete pad for the pad mounted transformer and provide a concrete pad under the Equipment Rack? Can you provide the required size of the concrete pad if required.

Answer: The concrete pad does not currently exist. The contractor is to install the concrete pad. The concrete pad for the service equipment rack and 45 kVA transformer (mounted on this pad – “pad mounted transformer” usually refers to a utility type transformer) is detailed on Sheet E3.0. Drawing E2.0 indicates the pad is existing. This is incorrect. The pad is new as shown on Sheet E3.0.

3. Drawing E2.0 – Detail 1 indicates providing a 200A Safety Switch for the Material Recovery Equipment Control Panel if required. Should this be an Alternate to our bid? There is no place on the bid form for an Alternate price.

Answer: We don't know if the Material Recovery Equipment Control Panel will have an internal main circuit breaker, so we showed an external safety switch to be safe. Please price this as an alternate so if the control panel does have an internal main breaker, there will be no need to provide the safety switch. A revised Bid Price Sheet is attached with the alternate noted.

NEW HANOVER COUNTY
Environmental Management Dept.
3002 U.S. Highway 421 North

Kim Roane, Business Officer
ph: 910-798-4402
fax: 910-798-4408

Wilmington, NC 28401

Email: kroane@nhcgov.com

**NEW HANOVER COUNTY
C&D ELECTRICAL SERVICE
Price Sheet/Bid Form**

TO: Kim Roane, Business Officer
New Hanover County
3002 Hwy. 421 North
Wilmington, NC 28401

DATE: _____ CONTRACTOR: _____

PHONE: _____ ADDRESS: _____

UNIT PRICE BID: The undersigned, having carefully examined the Instructions to Bidders, C&D Electrical Service, RFB # DEM-16003, including the following addenda;

ADDENDUM # _____ DATED: _____

ADDENDUM # _____ DATED: _____

ADDENDUM # _____ DATED: _____

As well as the premises and conditions affecting the work, proposes to furnish all services, labor, materials and equipment called for to complete the services in accordance with the contract documents for the following price:

C&D Electrical Service : \$ _____ **flat rate total**

Alternate 1 (Providing a 200A Safety Switch for the Material Recovery Equipment Control Panel if not present)
\$ _____ **Alternate 1**

Signature

Title

State of Incorporation