

Addendum 3
 Blue Clay Road Business Park
 March 23, 2023


BID DATE: March 31, 2023 at 3:00 PM.

TO ALL BIDDERS: Below are clarifications to the Bid Documents for this project. This Addendum forms a part of the Contract Documents and modifies the original bidding documents as noted below. Acknowledge receipt of this Addendum in the Bid Documents. Failure to do so may subject Bidder to disqualification.

SCOPE: This Addendum No. 3 consists of pages AD3-1 through AD3-2 And covers the following changes to the Project Manual and Bid Drawings.

Clarifications:

- This is to be bid as a lump sum project.
- Stockpile locations are temporary only. Unsuitable material needs to be disposed of offsite prior to completion of construction.
- Curb and gutter to be used:



STANDARD 24" CURB SECTION

- Inspections may be performed by the County, Engineer and/or 3rd party testing firms.
- Bore and jack length is per the Bid Drawings.
- Stormwater Control Measure outlet structures are to use CL-III RCP with O-ring gaskets. Other stormwater pipes are to be CL-IV.
- A quarterly service contract for the generator shall be provided in accordance with part 3.7 of specification section 26 32 13.
- Precast concrete sewer structures shall be coated in accordance with specification section 33 05 13 part 3.3.G unless otherwise noted on the Plans.
- CFPUA's preferred SCADA vendor is Revere Control Systems. Contractor shall coordinate SCADA integration needs with CFPUA prior to start of construction.